

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

Ergon Asphalt and Emulsions Incorporated 450 Funston Road Kansas City, KS 66115

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Blackhawk 5300 Series Modified Bitumen Adhesive (7U)

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 11-0301.01 and consists of pages 1 through 3. The submitted documentation was reviewed by Jorge L. Acebo.

MIAMI-DADE COUNTY
APPROVED

NOA No.: 13-0117.01 Expiration Date: 02/06/18 Approval Date: 01/31/13 Page 1 of 3

ROOFING COMPONENT APPROVAL

<u>Category</u>: Roofing

Sub-Category: Cements-Adhesives-Coatings

Materials: Asphalt

SCOPE:

This approves **Blackhawk 5300 Series Modified Bitumen Adhesive (7U)** as manufactured by **Ergon Asphalt and Emulsions Incorporated,** as described in this Notice of Acceptance. The use of this acceptance is limited to those roof assemblies where this product or an approved ASTM D3019 generic adhesive is specified.

EVIDENCE SUBMITTED

Test Agency	Test Identifier	Test Name/Report	Date
Underwriters Laboratories, Inc.	88NK19721	UL 790	02/06/89
Momentum Technologies, Inc.	EX24F2D	ASTM D-3019	08/05/02
PRI Construction Materials Technologies, LLC	EATC-008-02-01	ASTM D-3019	09/16/11

MANUFACTURING LOCATION

1. Kansas City, KS

PHYSICAL PROPERTIES OF COMPONENTS

Trade Name: Blackhawk 5300 Series Modified Bitumen Adhesive (7U)

Thickness: See Systems Approvals Below.

Specifications: ASTM D 3019 Type III

Description: A brush, squeegee or spray grade modified asphalt adhesive for use in adhering

sand or talc-backed APP and SBS modified bitumen roofing membranes. Apply evenly at a rate of 1.5-2 gal/100 sq. ft. Application over porous substrates, increase application rates to 3-4 gal/100 sq. ft. Note: Not for use with APP modified bitumen membranes or membranes having a plastic or polyethylene

backing.

Container Size: 5, 55 or 350 gallons returnable tote tanks. Note cautions on container label.

Systems Approvals: Methods of application and quantities shall comply specific Roof Assembly,

Product Control Notice of Acceptance.



NOA No.: 13-0117.01 Expiration Date: 02/06/18 Approval Date: 01/31/13 Page 2 of 3

LIMITATIONS

- 1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire rating of this product.
- 2. Ergon Asphalt and Emulsions Incorporated's products shall not be applied in inclement weather conditions.
- 3. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
- 4. All products listed herein shall have an unannounce follow-up quality control program from an approved listing agency. Follow up test results shall be made available to Miami-Dade Product Control upon request.
- 5. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below

MIAMI-DADE COUNTY
APPROVED

- 6. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
- 7. Ergon Asphalt and Emulsions Incorporated's products shall be applied in accordance with manufacturer's published application instructions.
- 8. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 13-0117.01 Expiration Date: 02/06/18 Approval Date: 01/31/13

Page 3 of 3